

ESTACION DEPURADORA DE AGUAS RESIDUALES DE

AGUILAR

ENERO 2008

AGUILAR

	CAUDAL m3/dia	ENTRADA								SALIDA							
		pH	Cdtv uS/cm2	SS mg/l	DQO mg/l	DBO5 mg/l	NTK mg/l	NH4 mg/l	Ptot mg/l	pH	Cdtv uS/cm2	SS mg/l	DQO mg/l	DBO5 mg/l	NTK mg/l	NH4 mg/l	Ptot mg/l
1																	
2	1388																
3	1105																
4	1196																
5	1131																
6	895																
7	1077																
8	868																
9	909																
10	1212	7,1	1189	82	200	90			8,0	1029	10,0	19,0	6,0				
11	877																
12	1105																
13	1150																
14	907																
15	1151																
16	936																
17	1047	7,4	1001	110	192	85		2,0	8,0	985	28,0	42,0	13,0			1,0	
18	1317																
19	926																
20	1172																
21	913																
22	1194																
23	1073																
24	978	7,5	1005	16	29		3,9	3,5	0,8	8,1	986	16,0	44,0		0,6	0,9	
25	1110																
26	420																
27	1882																
28	1044																
29	1152																
30	1100																
31	1197	7,3	966	84	189		8,4	3,1	1,4	7,4	1008	14,0	54,0		4,9	0,8	

