

MARZO

2012

FUENMAYOR

	CAUDAL m3/d	ENTRADA									SALIDA							
		pH	COND20 μS/cm	MES mg/L	MES-VOL %	DQO_D mg/L	DBO5 mg/L	N_T mg/L	NH4 mg/L	P_TOT mg/L	pH	COND20 μS/cm	MES mg/L	DQO_D mg/L	DBO5 mg/L	N_T mg/L	NH4 mg/L	P_TOT mg/L
1	4296																	
2	3724																	
3	4371																	
4	5069																	
5	4900	7,9	1438	56		146	30	37,9	20,8	3,2	7,8	1411	4,0	16,7	1,0	9,3	0,1	0,5
6	4181																	
7	4217	8,2	1137	82		172					7,9	1100	6,0	20,0				
8	4217																	
9	4147																	
10	4268																	
11	3701																	
12	4366	7,8	1254	124		289					7,7	1212	5,0	19,3				
13	4383																	
14	4449	7,8	1336	136		524					7,7	1168	5,0	18,3				
15	4523																	
16	4642																	
17	4844																	
18	1241																	
19	8416	7,9	1273	194		409		58,0	32,4	5,3	7,8	1234	4,0	16,7		9,0	0,0	0,8
20	4451																	
21	5876	8,2	1303	98		290					7,6	1107	6,0	16,9				
22	4191																	
23	4466																	
24	4301																	
25	4156																	
26	4443	7,5	1519	180		549	477				7,8	1120	4,0	15,7	6,0			
27	3782																	
28	3547	7,8	1520	82		191					7,7	1122	15,0	25,9				
29	3686																	
30	3058																	
31	3762	8,0	1311	64		144					7,8	1353	4,0	16,1				

