









MAYO 2010

FUENMAYOR

	CAUDAL m3/dia	ENTRADA								SALIDA							
		pH	Cdtv uS/cm2	SS mg/l	DQO mg/l	DBO5 mg/l	NTK mg/l	NH4 mg/l	Ptot mg/l	pH	Cdtv uS/cm2	SS mg/l	DQO mg/l	DBO5 mg/l	NTK mg/l	NH4 mg/l	Ptot mg/l
1	2368																
2	2223																
3	2939	7,7	1034	20	64	23	13,7	0,4	1,5	7,6	1348	8,0	15,4	1,7	10,5	0,2	2,0
4	4090																
5	3191	7,7	1469	130	277	210				7,6	1377	5,0	16,2	1,2			
6	3556																
7	4462																
8	3620																
9	4352																
10	4176	7,3	1416	158	148	99				7,9	1406	6,0	12,8	1,7			
11	4136																
12	4219	7,4	738	36	63	31				7,3	738	20,0	24,9	4,5			
13	5353																
14	4675																
15	3593																
16	3672																
17	2846	7,5	1438	100	187	126	28,6	15,3	3,3	7,4	1198	9,0	22,2	2,4	10,7	3,0	0,4
18	5141																
19	3985	7,5	1165	172	213	127				7,5	1216	14,0	21,5	1,6			
20	2301																
21	5833																
22	3449	7,4	1256	138	301	228				7,3	1056	7,0	20,3	1,3			
23	3351																
24	2192																
25	3293																
26	3844	7,3	1225	192	356					7,3	1246	5,0	15,8				
27	3329																
28	3973																
29	3968																
30	4029																
31	4219	7,6	1425	182	146					7,8	1316	4,0	14,8				















