

ESTACION DEPURADORA DE AGUAS RESIDUALES DE

RINCON OLIVEDO

ENERO 2008

RINCON OLIVEDO

	CAUDAL m3/dia	ENTRADA								SALIDA							
		pH	Cdtv uS/cm2	SS mg/l	DQO mg/l	DBO5 mg/l	NTK mg/l	NH4 mg/l	Ptot mg/l	pH	Cdtv uS/cm2	SS mg/l	DQO mg/l	DBO5 mg/l	NTK mg/l	NH4 mg/l	Ptot mg/l
1																	
2	102																
3	119																
4	200																
5	145																
6	135																
7	129																
8	171																
9	180																
10	186	7,6	1432	66	225	145				7,6	1637	11,0	24,0	9,0			
11	181																
12	255																
13	226																
14	156																
15	166																
16	182																
17	165	8,7	1502	154	329	190			9,7	8,7	1570	11,0	48,0	10,0		2,6	
18	201																
19	146																
20	281																
21	223																
22	248																
23	172																
24	219	7,8	1257	52	137		16,4	23,4	3,1	7,8	1556	34,0	109,0			2,3	
25	209																
26	175																
27	220																
28	215																
29	159																
30	224																
31	211	8,5	1611	344	796		3,1	77,8	10,8	8,5	1466	8,0	39,0			2,4	

