

AGOSTO 2010

RINCON DE SOTO

	CAUDAL m3/dia	ENTRADA									SALIDA							
		pH	Cdtv uS/cm2	SS mg/l	SSV %	DQO mg/l	DBO5 mg/l	NTK mg/l	NH4 mg/l	Ptot mg/l	pH	Cdtv uS/cm2	SS mg/l	DQO mg/l	DBO5 mg/l	NTK mg/l	NH4 mg/l	Ptot mg/l
1	4557																	
2	2445																	
3	3887	7,4	1800	140		282	155	24,2	9,0	3,9	7,2	1525	8,0	17,1	9,0	7,3	5,8	0,6
4	3556																	
5	4151																	
6	3690																	
7	3292																	
8	4132																	
9	3006																	
10	3562	7,5	1502	160		175					7,3	1322	8,0	16,0				
11	4046																	
12	3544																	
13	3348																	
14	3608																	
15	3231																	
16	3506																	
17	3512	7,6	1800	140		446					7,5	1620	10,0	17,6				
18	4001																	
19	4261																	
20	3823																	
21	3566	7,3	1400	130		416					7,3	1360	9,0	18,1				
22	3065																	
23	4638																	
24	4298																	
25	3970																	
26	4074																	
27	3604																	
28	4704																	
29	4002																	
30	3466																	
31	3761	7,3	1540	380		574					7,3	1320	10,0	16,8				

