

MARZO

2011

TORRECILLA

	CAUDAL m3/d	ENTRADA									SALIDA							
		pH	COND20 μS/cm	MES mg/L	MES-VOL %	DQO_D mg/L	DBO5 mg/L	N_T mg/L	NH4 mg/L	P_TOT mg/L	pH	COND20 μS/cm	MES mg/L	DQO_D mg/L	DBO5 mg/L	N_T mg/L	NH4 mg/L	P_TOT mg/L
1	407																	
2	256																	
3	389	7,9	532	10		22	12	12,8	1,5	0,2	7,5	506	4,0	7,8	1,0	7,3	0,0	0,3
4	399																	
5	563																	
6	441																	
7	467																	
8	505																	
9	500																	
10	341	8,0	595	12		20	8				7,6	516	4,0	8,4	0,5			
11	572																	
12	431																	
13	467																	
14	355																	
15	850																	
16	1225																	
17	1078																	
18	887																	
19	692	7,6	569	21		61	40				7,7	594	9,0	10,0	1,3			
20	716																	
21	558																	
22	550																	
23	739																	
24	644																	
25	567																	
26	898																	
27	873																	
28	680																	
29	665																	
30	754																	
31	796	7,9	537	6		19					7,7	519	4,0	20,0				

