

ESTACION DEPURADORA DE AGUAS RESIDUALES DE

VILLOSLADA

ENERO 2011

2011

VILLOSLADA

2010S0033|U

	CAUDAL m3/d	ENTRADA									SALIDA							
		pH	COND20 µS/cm	MES mg/L	MES-VOL %	DQO_D mg/L	DBO5 mg/L	N_T mg/L	NH4 mg/L	P_TOT mg/L	pH	COND20 µS/cm	MES mg/L	DQO_D mg/L	DBO5 mg/L	N_T mg/L	NH4 mg/L	P_TOT mg/L
1	191																	
2	110																	
3	104																	
4	158	7,5	423	80		126	97				7,1	416	4,0	15,3	1,8			
5	124																	
6	178																	
7	138																	
8	194																	
9	81																	
10	100	8,0	653	102		258	202	37,8	18,9	3,5	7,1	300	4,0	10,3	0,3	12,7	0,9	1,1
11	96																	
12	82																	
13	89																	
14	120																	
15	100																	
16	100																	
17	111																	
18	88																	
19	120																	
20	119																	
21	141																	
22	75																	
23	128																	
24	116	8,7	334	72		193	133				7,6	335	4,0	16,9	1,2			
25	88																	
26	120																	
27	92																	
28	82																	
29	80																	
30	74																	
31	111	7,8	1083	122		337					6,3	300	5,0	12,9				

