

MARZO 2008

AUSEJO

	CAUDAL m ³ /dia	ENTRADA								SALIDA							
		pH	Cdtv uS/cm2	SS mg/l	DQO mg/l	DBO5 mg/l	NTK mg/l	NH4 mg/l	Ptot mg/l	pH	Cdtv uS/cm2	SS mg/l	DQO mg/l	DBO5 mg/l	NTK mg/l	NH4 mg/l	Ptot mg/l
1	421																
2	441																
3	192	8,2	2750	484	1224		91,9	68,5	18,3	7,7	1810,0	4,0	20,6		0,6	0,5	7,8
4	350																
5	401	7,9	2800	156	181					7,7	1441,0	12,0	35,0				
6	487																
7	428																
8	406																
9	437																
10	448	7,6	2700	736	1517					7,7	2800,0	14,0	45,7				
11	468																
12	434																
13	408																
14	425																
15	408																
16	476																
17	366	7,6	3100	676	1798	1018				7,6	2400,0	9,0	32,4	2,9			
18	501																
19	542																
20	253																
21	434																
22	417																
23	264																
24	520	8,7	1400	208	575	270				7,1	1700,0	13,0	49,8	6,9			
25	434																
26	348	8,0	1800	94	297					7,6	1500,0	6,0	34,0				
27	421																
28	549																
29	348																
30	384																
31	304	8,4	2320	516	1065					7,6	1780,0	11,0	38,4				

