

OCTUBRE**2012****RIBAFRECHA**

2010S0035|U

	CAUDAL m3/día	ENTRADA									SALIDA								
		pH	COND20 µS/cm	MES mg/L	MES-VOL %	DQO_D mg/L	DBO5 mg/L	N_T mg/L	NH4 mg/L	P_TOT mg/L	pH	COND20 µS/cm	MES mg/L	DQO_D mg/L	DBO5 mg/L	N_T mg/L	NH4 mg/L	P_TOT mg/L	
1	337	8,0	1495	40		87		33,3	21,3	2,4	7,8	1113	8,0	11,5		11,5	0,2	2,8	
2	318																		
3	332	8,2	2020	144		370	109				7,9	2222	11,0	22,3	1,0				
4	388																		
5	466																		
6	320																		
7	464																		
8	453	8,0	1654	102		304					7,8	2310	9,0	19,8					
9	593																		
10	586	7,7	1330	138		294					7,8	2340	4,0	17,0					
11	407																		
12	445																		
13	467																		
14	712																		
15	533	8,4	1778	108		193					7,9	1293	5,0	12,7					
16	646																		
17	661	7,9	1470	46		73					8,0	1749	16,0	14,3					
18	846																		
19	461																		
20	1124																		
21	576																		
22	402	8,0	1684	70		120					7,9	1915	10,0	17,3					
23	580																		
24	397	8,3	1860	114		240					8,0	1873	4,0	19,1					
25	520																		
26	269																		
27	451																		
28	407																		
29	379	8,5	1770	160		328					8,0	1680	1,0	19,7					
30	273																		
31	447	8,3	1790	260		477					8,0	1714	11,0	32,8					

