









AGOSTO 2010

RINCON DE OLIVEDO

	CAUDAL m3/dia	ENTRADA									SALIDA							
		pH	Cdtv uS/cm2	SS mg/l	SSV %	DQO mg/l	DBO5 mg/l	NTK mg/l	NH4 mg/l	Ptot mg/l	pH	Cdtv uS/cm2	SS mg/l	DQO mg/l	DBO5 mg/l	NTK mg/l	NH4 mg/l	Ptot mg/l
1	219																	
2	99																	
3	140	7,2	1110	180		473	205	42,2	15,0	4,3	7,2	1095	9,0	25,2	12,0	6,8	2,4	0,9
4	141																	
5	118																	
6	154																	
7	202																	
8	164																	
9	178																	
10	146	7,5	1250	170		300					7,2	1115	7,0	25,0				
11	139																	
12	146																	
13	158																	
14	146																	
15	152																	
16	145																	
17	130	7,4	1100	100		476					7,4	1020	7,0	25,6				
18	153																	
19	161																	
20	145																	
21	194	7,8	1300	145		671					7,7	1010	8,0	25,1				
22	180																	
23	111																	
24	184																	
25	130																	
26	158																	
27	145																	
28	180																	
29	154																	
30	130																	
31	141	7,3	1215	315		531					7,2	1028	9,0	22,2				









