

JULIO 2010

VILLOSLADA DE CAMEROS

	CAUDAL m3/dia	ENTRADA									SALIDA							
		pH	Cdtv uS/cm2	SS mg/l	SSV %	DQO mg/l	DBO5 mg/l	NTK mg/l	NH4 mg/l	Ptot mg/l	pH	Cdtv uS/cm2	SS mg/l	DQO mg/l	DBO5 mg/l	NTK mg/l	NH4 mg/l	Ptot mg/l
1	67																	
2	200																	
3	198																	
4	74																	
5	73																	
6	103																	
7	124																	
8	73	7.3	557	134		567	439	46.9	41.2	4.7	7.6	422	5.0	38.7	2.3	10.1	5.8	0.5
9	101																	
10	138																	
11	60																	
12	98	7.9	516	254		513	427				7.9	297	6.0	18.8	1.0			
13	77																	
14	86																	
15	76																	
16	108																	
17	77																	
18	82																	
19	68	8.0	590	252		470	366				7.9	326	4.0	17.8	3.4			
20	90																	
21	137																	
22	67																	
23	117																	
24	110																	
25	84																	
26	108	7.8	497	192		686	466				7.7	280	5.0	23.2	4.2			
27	100																	
28	107																	
29	61																	
30	131																	
31	74	7.9	589	206		601	453				7.8	442	12.0	29.4	4.1			

