

OCTUBRE**2012****ALCANADRE**

2008S0398|U

	CAUDAL m3/dia	ENTRADA									SALIDA							
		pH	COND20 µS/cm	MES mg/L	MES-VOL %	DQO_D mg/L	DBO5 mg/L	N_T mg/L	NH4 mg/L	P_TOT mg/L	pH	COND20 µS/cm	MES mg/L	DQO_D mg/L	DBO5 mg/L	N_T mg/L	NH4 mg/L	P_TOT mg/L
1	426	7,5	2090	228		534		59,7	39,4	7,2	7,5	891	4,0	11,8		1,8	0,2	0,3
2	344																	
3	358	7,5	1591	54		225					7,5	1260	19,0	36,7				
4	272																	
5	298																	
6	333																	
7	468																	
8	442	7,1	2800	384		992					7,7	1564	5,0	15,0				
9	248																	
10	872	7,2	3010	60		298					7,5	1699	4,0	18,8				
11	932																	
12	818																	
13	494																	
14	626																	
15	443	7,6	1979	120		172	74				7,3	1173	7,0	13,4	1,3			
16	327																	
17	382	7,9	2800	50		153					7,3	1304	6,0	19,5				
18	458																	
19	722																	
20	1938																	
21	1619																	
22	831	7,9	1218	82		183					7,5	547	6,0	10,7				
23	433																	
24	897	7,5	1485	52		241					7,4	948	4,0	16,2				
25	925																	
26	490																	
27	500																	
28	535																	
29	496	7,7	1458	32		106					7,5	1015	6,0	16,6				
30	484																	
31	359	7,6	2700	68		207					7,7	1418	7,0	26,0				

